

Fire-Lite Alarms ECC-50/100 Firmware Update Release Notes: 2/23/16

Important Note: Updating firmware to Version V1.2B3.

When updating the firmware on the ECC-50/100, it is important to download, backup and convert the existing site specific programming database from the panel to the new format required by firmware version V1.2B3. This can be accomplished by following the firmware update and database conversion procedures listed on the website. Following these procedures allows for the password and site specific settings to be maintained on the existing ECC-50/100 when updating from an older firmware version to the new V1.2B3 version.