

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7120-0075:0171

Page 1 of 1

**CATEGORY:** 7120 -- ANNUNCIATORS

**LISTEE:** FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653  
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309  
Email: Brian.Reynolds2@Honeywell.com

**DESIGN:** Models RZA-5F, RZA-4XF Remote Zone Annunciator and LED-10, LED-10L Remote Fire Annunciator. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The RZA-5F and RZA-4XF are intended to be installed on a standard listed single gang electrical back box. The LED-10 and LED-10L are intended to be installed on a three gang electrical back box.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as remote annunciators for use with listee's separately listed electrically and functionally compatible fire alarm control units.

**NOTE:**

\*Rev. 05-06-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*