

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0075:0184

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Models BG-12, BG-12S, BG-12NC, BG-12W, BG-12LW, BG-12WP, BG-12LWP, BG-12L, BG-12LX, BG-12LA, BG-12PS, BG-12LSP, BG-12SP, BG-12LR, BG-12LRA, BG-12LAO, BG-12LAOB, BG-12-LO, BG-12LOB, BG-12LPS, BG-12LPSP, BG-12SL, UT-PS1 and UT-PS2 fire alarm pull boxes. The BG-12 series is a dual action pull station that has normally open switch contacts. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire alarm boxes for use with separately listed compatible fire alarm control units. Models BG-12WP, BG-12W, BG-12LW and BG-12LWP are intended for outdoor use when installed with Model WP-10 back box. Models BG-LAOB and BG-12LOB are intended for outdoor use when installed with Model WBB or WP-10 back box.

* These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition and California amendments.

XLF: 7150-0028:0199

*Updated 08-17-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division