

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 3240-0075:0196

CATEGORY: 3240 -- DUCT SMOKE DETECTOR HOUSING/BASE

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Model D350P, D350PL, D350RP, and D350RPL automatic smoke detector for duct application. The unit consists of a plastic enclosure, relay, electrical components, listed open area detector, and a sampling and exhausted tube. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, and UL label.

APPROVAL: Listed as duct smoke detector for use with listee's separately listed compatible fire alarm control units. Suitable for use in ducts where air velocity is between 100 and 4000 fpm.

NOTE:

*Rev. 05-06-05KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division