

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0075:0203
CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

Page 1 of 1

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309
Email: Brian.Reynolds2@Honeywell.com

DESIGN: Models AD350 photoelectric type smoke detector. Model employs a supplemental heat sensor to assist the smoke detector. This heat sensor is not intended for use as a heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations. Models AD350 photoelectric type smoke detector. Model employs a supplemental heat sensor to assist the smoke detector. This heat sensor is not intended for use as a heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as photoelectric type smoke detector for use with listee's separately listed compatible base and fire alarm control units. Suitable for open areas on vertical walls or ceilings and installations inside air ducts with air velocities between 0-4000 fpm.

NOTE:

*Rev. 05-06-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division