

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7120-0075:0211

**CATEGORY:** 7120 -- ANNUNCIATORS

**LISTEE:** FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653  
Contact: Brian Reynolds (203) 484-7161 Fax (203) 484-7309  
Email: Brian.Reynolds2@Honeywell.com

**DESIGN:** Model ANN-80 and \*ANN-80W remote fire annunciators. Unit is a 80-character, supervised backlit LCD fire annunciator. Communication between the control panel and the annunciator is accomplished over a two-wire serial interface employing the ANN-BUS protocol. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product number, electrical rating and UL label.

**APPROVAL:** Listed as an annunciators for use separately listed compatible fire alarm control units. Refer to Manufacturers Installation Manual for details.

**NOTE:**

\*Rev. 04-28-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**  
*Fire Engineering Division*