

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-1439:0100

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: KILLARK ELECTRIC MFG3940 Martin Luther King Dr, St. Louis, MO 63113
Contact: Thomas Michalski (314) 531-0460 Fax (314) 531-7164
Email: tmichals@hep.hubbell.com

DESIGN: Models XAL and XAS noncoded fire alarm boxes, followed by 1, 2, 3, 4, 5, 6, 13, 14, 41, 42, 43, 44, 45, or 46, followed by 1, 2, 3, 4, 5, 6, 7, or 8. Conduit sizes in 1/2", 3/4" and 1". Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 6 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm boxes for use with separately listed compatible fire alarm control panels. Suitable for use in Class I, Group C and D, and Class II, Groups E, F, and G, and Class III hazardous locations.

* These manual pull boxes do not meet the requirements of UL Standard 38, 1999 Edition and California amendments.

*Updated 06-22-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division