



MS-25 Battery Calculation

Secondary Power Source Requirements

Device Type	Standby Current (amps)				Secondary Alarm Current (amps)				
	Qty		Current Draw	Total	Qty		Current Draw	Total	
1. Control Panel									
Main Circuit Board	1	x	0.135000	= 0.135000	1	x	0.220000	= 0.220000	
2. Addressable SLC Devices									
HFS-P	0	x	0.000270	=	0	x	0.000270	=	
HFS-PT	0	x	0.000270	=	0	x	0.000270	=	
HFS-D	0	x	0.000270	=	0	x	0.000270	=	
HFS-T	0	x	0.000270	=	0	x	0.000270	=	
HFS-MM	0	x	0.000375	=	0	x	0.000375	=	
HFS-MR	0	x	0.000255	=	0	x	0.000255	=	
BG-12LX	0	x	0.000375	=	0	x	0.000375	=	
Total SLC Devices	0								
3. Auxiliary Devices									
Auxiliary Device 1	0	x	0.000000	=	0	x	0.000000	=	
Auxiliary Device 2	0	x	0.000000	=	0	x	0.000000	=	
Auxiliary Device 3	0	x	0.000000	=	0	x	0.000000	=	
Auxiliary Device 4	0	x	0.000000	=	0	x	0.000000	=	
Auxiliary Device 5	0	x	0.000000	=	0	x	0.000000	=	
4. Notification Appliance Circuits									
NAC 1					0	x	0.000000	=	
NAC 2					0	x	0.000000	=	
Total Standby Load				0.135000	Total Alarm Load				0.220000



MS-25 Battery Calculation

Secondary Power Source Requirements

Calculation in Total Sheet

		Required Standby Time in Hours		
		24 Hours		
Standby Load Current	0.13500 Amps	x	24	= 3.240 AH
		Required Alarm Time in Minutes		
		20 Minutes		
Alarm Load Current (Amps)	0.22000 Amps	x	0.334	= 0.073 AH
Total Current Load				3.313 AH
Multiply by the Derating Factor			1.2	= x 1.20
Total Ampere Hours Required				3.98 AH

Recommended Batteries: BAT-1270 - 7AH Batteries

Battery Check

The batteries can be charged by the MS-25 Charger.

The batteries can be housed in the MS-25 Cabinet.

Current Draw Check

NAC#1 current is within the limitations of the circuit.

NAC#2 current is within the limitations of the circuit.

MS-25 Control Panel:

The output current is within the panel's limitations.