

## TECHNICAL BULLETIN

### Daylight Savings Time Panel Adjust

**February 12, 2007**  
**Document FLTB07-02-2**

Dear Business Leader:

With the adoption of the U.S. Energy Act of 2005, as of March, 2007, the National observance of the daylight savings period will be extended by 4 weeks. The original beginning and ending dates of the first week in April to last week in October will change to the second Sunday in March and first Sunday in November

Customers should be aware that only the following products contain DST settings: MS-9050UD, MS-9200UD, MS-9200UDLS and MS-9600. DST is both automatic and programmable in all of these panels. Existing installations will need to be adjusted to the new beginning and ending dates. Once this change is made, the panel will automatically adjust every year. The only panel operation affected by DST is the central station test call feature.

As software maintenance upgrades are released for each panel, the new DST period will be shipped defaulted to the new start and end dates. Until that time, installers must change the default DST start and stop dates to the new dates.

Sincerely,



Nick Martello  
FireLite Marketing Director