



One Fire-Lite Place
Northford, CT 06472-1653 USA

203-484-1200
203-484-1036 Fax

May 12, 2010

To Whom It May Concern:

Re: MSDS sheets for Ionization detectors

MSDS Sheets are not required for FireLite ionization smoke detectors based on the following information:

1. MSDS sheets are not required for consumer electronic products (i.e. smoke detectors, telephones, keyboards, etc). MSDS sheets relate to specific materials and not completed products.
2. Product manufacturers are governed to possess an MSDS sheet for each material used in the production process and related operations. Radioactive materials are exempt from MSDS requirements due to the sensitive nature of information and increased governmental oversight on many other levels. See the following link to the OSHA website for additional information:
http://www.osha.gov/pls/oshaweb/owadisp.show_document?p_table=standards&p_id=10099

Should you have any questions or require further information please do not hesitate to contact me.

Very truly yours,

A handwritten signature in black ink, appearing to read "Richard A. Bauer".

Richard A. Bauer
Director of Marketing, Vendor Products
Richard.Bauer@Honeywell.com
(203) 484-6502