

# Power-limited Notification Appliance Power

The +24 VDC regulated, nonresettable power available on TB2 Terminal 3 is power-limited only when used with the minus return on TB2 Terminal 4. *Do not use the minus return on TB2 Terminal 2 with the +24 VDC power on TB2 Terminal 3. Refer to the illustration below.*

# MPS-24B/BE/BF Technical Supplement

Document 50289 Rev A 5/4/95 ECN 95-219

