

Central Station Receiver Addendum

Document 52458 Rev A 01/20/05 ECN 05-021

Compatible UL Listed Central Station Receivers

Fire Alarm Control Panels, which incorporate a Digital Alarm Communicator/Transmitter, send vital information about the control panel status to compatible UL-listed Central Station Receivers.

IMPORTANT! *Installers must ensure that the Digital Alarm Communicator/Transmitter is compatible with the Central Station Receiver, utilized by the monitoring service, prior to installation.*

The Compatibility Tables included in the manuals provide a list of compatible receivers and associated software versions for the receivers. Changes in the hardware and/or software by the receiver manufacturers may affect the receiver compatibility with FACPs.

It is the installer's responsibility to ensure that the monitoring service receiver is compatible with the Digital Alarm Communicator/Transmitter which is incorporated in the FACP. After completing the installation, communication between the Digital Alarm Communicator/Transmitter and the Central Station Receiver must be tested and verified.