

Product Retirement Announcement



B501BH and B501BHT Sounder Bases

October 9, 2008
Document FLPR08-10-1

Dear Valued Customer,

As part of Fire-Lite ongoing efforts to prepare for the upcoming UL 864 9th Edition deadline the following sounder bases will be discontinued effective November 15, 2008:

<u>Item #</u>	<u>Description</u>
B501BH	Sounder Base, Constant Tone, UL 8 th
B501BHT	Sounder Base, Temporal Three Tone, UL 8 th

The replacement products, which are UL 864 9th Edition compliant and fully backwards compatible, are as follows:

<u>Item #</u>	<u>Description</u>
B501BH-2	Sounder Base, Constant Tone, UL 9 th
B501BHT-2	Sounder Base, Temporal Three Tone, UL 9 th

The UL 864 9th edition requirements dictate that all fire alarm outputs need to activate in 10 seconds or less. The 8th Edition products (B501BH and B501BHT) have a delay time of 4 – 20 seconds which does not meet the UL 864 9th edition requirements. The delay time for the replacement products (B501BH-2 and B501BHT-2) will be a minimum of 0.75 seconds and a maximum of 3.55 seconds.

Please anticipate any future need for the B501BH and B501BHT and place your final orders as soon as possible. All orders will be fulfilled on a first-in / first-out basis while supplies last.

We appreciate your cooperation during this transition. Please contact your Regional Sales Manager or Fire-Lite Customer Service Representative at 1-800-627-3473, if you have any questions regarding this announcement.

Thank you for your continued business.

Sincerely,

A handwritten signature in cursive script that reads "Bill Brosig".

Bill Brosig
Fire-Lite Product Manager

FLPR08-10-1